



File: 9000488

February 10, 2020

**British Columbia Hydro and Power Authority**

12<sup>th</sup> Floor - 333 Dunsmuir Street  
Vancouver, BC  
V6B 5R3

**Dear Sir or Madam:**

**Re: Short Term Use Approval Application – 9000488 (Peace River Borrow Pit)**

Approval for the above has been granted and is attached for your perusal. The Approval holder is required to adhere to all other applicable Provincial and Federal regulations.

To protect the quality and safety of our groundwater resources all wells and associated works related to a groundwater diversion, storage and use must comply with the Water Sustainability Act and Groundwater Protection Regulation which requires water wells in British Columbia to be properly constructed, maintained, and, at the end of their service, deactivated and decommissioned. For more information on well owner requirements under the Groundwater Protection Regulation please visit <http://www2.gov.bc.ca/gov/content/environment/air-land-water/water/groundwater-wells>.

Section 105 of the *Water Sustainability Act* gives the recipient of this notice the right to appeal my decision. You may file an appeal within 30 days of the date indicated on this letter. Information on filing an appeal can be found on the Environmental Appeal Board WEB site at <http://www.eab.gov.bc.ca/>.

Yours truly,

Dave Francis  
Water Manager

Enc.

Ministry of Forests, Lands, Natural Resource Operations and Rural Development, Resource Stewardship Division, Water Management Branch, Gypsy Fisher, P.Geo.  
EDI Environmental Dynamics Inc., Jason Yarmish, Prince George BC



# Province of British Columbia

## *Water Sustainability Act*

---

### **Section 10 (1)**

### **Use Approval**

**British Columbia Hydro and Power Authority, 12<sup>th</sup> Floor-333 Dunsmuir Street, Vancouver, BC V6B 5R3** and their agents are hereby authorized to divert and use water as follows:

- 1) The rights are granted for the unconsolidated aquifer which the groundwater point of diversion is located.
- 2) The point of diversion is located at:
  - Lat: 56.240622 Long: -121.3010446
- 3) This Approval does not authorize entry onto privately held or Crown land.
- 4) The purposes for which water is to be used under this Approval is Industrial as listed below;
  - Water Well Drilling and Transportation or Utility Corridor Management
- 5) The maximum total annual volume of water that can be diverted under this Approval is 28,800 cubic metres per year. The maximum daily withdrawal is 150 cubic metres per day and the pump rate shall not exceed 0.074 cubic metres per second.
- 6) This Approval has been granted to use the water from the date of issuance to November 30, 2021.
- 7) The holder of this Approval shall take reasonable care to avoid damaging any land, works, trees or other property, and shall make full compensation to the owners for any damage or loss resulting from the exercise of the rights granted with this Approval.
- 8) The works authorized are screened intakes, pumps, pipelines or hoses and water trucks.
- 9) The holder of this Approval will initiate those sections under the Environmental Impact Statement (EIS), as it relates to this project to protect fish and fish habitat, vegetation and ecological communities, wildlife and heritage resources associated with these works.
- 10) Authorized equipment shall be free of external grease, oil or fluid leaks while operating in the vicinity of any watercourse.

- 11) To limit the spread of invasive weeds, all authorized equipment used shall be inspected and weeds shall be removed before leaving the intake site.
- 12) This Approval does not authorize any in-stream work.
- 13) Daily and total volumes of water diverted for this project shall be retained and made available for review upon request.
- 14) A copy of this Approval and the water records must be available upon request and retained by the various pump operators/contractors for inspection.
- 15) The Holder of this Approval must ensure that any incidence of high significance of non-conformance to conditions of this Approval are reported to IE or IEM within 24 hours of discovery and the submission of a report within 5 days of that occurrence, in a form and manner acceptable to the Water Manager.

A handwritten signature in black ink, appearing to read "D Francis", written in a cursive style.

Dave Francis  
Water Manager

**Date Issued: February 10, 2020**

**Approval/File No. 9000488**